

## CHAPTER 5 – BUILDINGS AND BUILDING REGULATIONS

### Sec. 5-113. Testing and records.

(a) *Device.* Each device shall be tested at least annually or more frequently if recommended by the manufacturer, or the department, at the consumer's or owner's expense.

(b) *Records.* Records submitted to the city shall be available for inspection by agency personnel.

(c) *Identification.* Each assembly shall have a tag attached listing the manufacturer and serial number of the assembly.

(d) *Log.* A maintenance log shall be maintained and include the following:

- (1) Date of each test.
- (2) Name and approval number of person performing the inspection or test.
- (3) Test results/inspection.
- (4) Repairs or servicing required.
- (5) Repairs and date completed.
- (6) Services performed and date completed.
- (7) Results of final test.

(e) *City records.* The department will maintain records of the types and locations of all assemblies used for the prevention of back flow in accordance with requirements of chapter 7, section H, paragraph 2, Arizona Department of Health Services Engineer Bulletin No. 10, Guidelines for the Construction of Water Systems, as amended.

(f) *Annual notification to test.*

- (1) The City shall notify the customer via first class mail at least 60 days before the annual test compliance due date for each backflow prevention assembly.
- (2) If by the annual compliance date the City does not receive the required test report, the City shall provide written notice via hand delivery or certified mail delivered to the customer of the City's intent to discontinue water service if the required annual test report is not received within five days of the confirmed delivery date.
- (3) The customer shall not test any backflow prevention assembly more than 60 days prior to the annual test due date, unless a waiver is requested in writing and granted with written City approval.

## CHAPTER 5 – BUILDINGS AND BUILDING REGULATIONS

(Code 1977, § 8-2-6)

(Ord. No. 2011-22, 11/1/2011, Amended) SUPP 2011-4