

CHAPTER 5 – BUILDINGS AND BUILDING REGULATIONS

Section 5-78. International Fuel Gas Code – Adopted and Amended.

(A) A certain document, one copy of which is on file in the City Clerk’s Office of the City of Peoria, being marked and designated as “International Fuel Gas Code, 2012 Edition,” published by the International Code Council is hereby adopted, as amended herein, as the Fuel Gas Code of the City of Peoria.

(B) The International Fuel Gas Code, 2012 Edition, is amended as follows:

(1) Chapter 1, “Scope and Administration” is hereby amended as follows:

101.1 Title. Insert the words “City of Peoria” in the name of jurisdiction.

101.2 Scope. Amend as follows by adding: Any references to the ICC Electrical Code shall be deleted and the words “Electrical Code adopted by the City of Peoria and amended from time to time” shall be inserted in lieu thereof.

101.3 Appendices. Amend Section 101.3, “Appendices,” by adding the following:

The following appendices are adopted:

APPENDIX A – SIZING AND CAPACITIES OF GAS PIPING

APPENDIX B – SIZING OF VENTING SYSTEMS SERVING APPLIANCES EQUIPPED WITH DRAFT HOODS, CATEGORY 1 APPLIANCES AND APPLIANCES LISTED FOR USE WITH TYPE B VENTS

APPENDIX C – EXIT TERMINALS OF MECHANICAL DRAFT AND DIRECT-VENT VENTING SYSTEMS

Section 103, “Department of Inspection,” is hereby amended as follows:

103.1 General. The Building Safety Division is hereby created and the executive official in charge thereof shall be known as the building official.

106 “Permits,” is hereby amended as follows:

106.6.2 Fee Schedule. Insert the words “Section 2-209 of the Peoria City Code, Table 2-209.”

106.6.3 Fee refunds. Delete in its entirety.

CHAPTER 5 – BUILDINGS AND BUILDING REGULATIONS

109 Means of Appeal. Delete in its entirety and amend as follows: “All appeals shall follow the provisions of the International Building Code, 2012 Edition, Section 113, and Chapter 5 of the Peoria City Code (1992) Section 5-9.”

(2) 404.12 Minimum burial depth. Delete in its entirety and amend as follows: “Underground metallic piping systems shall be installed a minimum depth of 12 inches (305 mm) below grade. Underground plastic piping systems shall be installed a minimum depth of 18 inches (457 mm) below grade.”

404.12.1 Individual outside appliances. Delete in its entirety.

(Ord. 07-32, 10/02/07, Enacted Sec 05-78) SUPP 2007-4

(Ord. 2012-08, 5/1/2012, Adopted 2012 Edition) SUPP 2012-2